

**BIDS AND AWARDS COMMITTEE FOR FREE WI-FI INTERNET ACCESS IN PUBLIC PLACES
PROJECT (BAC4FREEWIFI)**

Supplemental Bid Bulletin No.3

**Supply, Delivery, Installation, Testing and Acceptance of One Lot Brand New Power
Generators for the Ten (10) Point of Presence Sites**

Bid Reference No. BAC4FREEWIFI-2016-02-001

Please be advised of the changes in the schedule of the Submission and Opening of Bids for this project:

Activity	Previous Schedule	Revised Schedule
Submission of Bids	21 March 2016 12 Noon	4 April 2016 12 Noon
Opening of Bids	21 March 2016 1 PM	4 April 2016 1 PM

After considering the queries, clarifications, recommendations and suggestions, the BAC4FREEWIFI hereby decides to include, revise, amend, delete and/or adapt the following provisions:

<u>ORIGINAL PROVISION</u>	<u>AMENDED PROVISION</u>
Section VII. Technical Specifications	
7.2.1.2. 4 hours Run test (without load) a. The engine should run continuously for 4 hours until manually stopped without any faults or alarms on the control panel.	7.2.1.2. 4 minutes Run test (without load) a. The engine should run continuously for 4 minutes until manually stopped without any faults or alarms on the control panel.

All terms, conditions and instructions to bidders specified in the Bidding Documents inconsistent with this Bid Bulletin are hereby superseded and modified accordingly.

Please use the following forms attached in this Supplemental Bid Bulletin:

- Revised Technical Specifications as of 18 March 2016

For information and guidance of all concerned.

Issued this 18th day of March 2016.

(Original Signed)

MARIA TERESA MAGNO-GARCIA
Chairperson, BAC4FREEWIFI



Revised Technical Specifications as of 18 March 2016

INSTRUCTION TO THE SUPPLIER: Indicate “COMPLY” per line number under Bidder’s Statement of Compliance if Bidder can meet the technical specifications and project requirements. **DO NOT LEAVE ANY BLANK. A “YES” or “NO” ENTRY WILL NOT BE ACCEPTED. FAILURE TO CONFORM WILL RESULT IN A RATING OF “FAILED”.**

SUPPLY, DELIVERY, INSTALLATION, TESTING AND ACCEPTANCE OF ONE LOT OF BRAND NEW POWER GENERATORS FOR THE TEN (10) POINT OF PRESENCE SITES

ITEM	MINIMUM SPECIFICATIONS	STATEMENT OF COMPLIANCE
1.	This tender is for the Supply, Delivery, Installation, Testing and Acceptance of brand new Generator Set with Automatic Transfer Switch (ATS) and other Complete Standard Accessories, one for each of the ten (10) Point of Presence Sites (PoPs).	
2.	The total of the Approved Budgetary Cost (ABC) for this tender is NINE MILLION FIVE HUNDRED THOUSAND PESOS (Php9,500,000.00).	
3.	The Supply, Delivery, Installation, Testing and Acceptance of all Generator Sets shall be made within NINETY (90) days from receipt of Notice to Proceed.	
4.1.	Minimum Capacity: 45 kVA, 125 Amperes ATS	
4.2.	Type: Diesel feed, silent type, weather proof	
4.3.	Voltage: 230-240 Volts, AC	
4.4.	Enclosure (Canopy): Original Equipment Manufacturer (OEM)	
4.5.	Frequency: 60 Hz	
4.6.	Power Factor: 80%	
4.7.	Revolution per Minute (RPM): 1,800	
4.8.	Phase: 3	
4.9.	Complete Standard Accessories: <ul style="list-style-type: none"> • Industrial Batteries • Fuel Base Tank • Industrial-Type Exhaust Silencer/Muffler • Auto-crank/Auto Start Module • In-house and hands-on training & orientation for proper Gen Set operation and basic maintenance/troubleshooting • One (1) Set of Operation and Maintenance Manuals, including Parts Manuals 	
4.10.	ISO Certification: ISO 9001:2008	
4.11.	Warranty: One (1) year on parts and service	
4.12.	Certification: Bidder/supplier must submit certification that their offered	

Supplemental Bid Bulletin No. 3

Supply, Delivery, Installation, Testing and Acceptance of One Lot Brand New Power Generators for the Ten (10) Point of Presence Sites

BAC4FREEWIFI-2016-02-001

	equipment is used in (1) United States of America or Canada; (2) Europe (Any country in Europe); and (3) Japan																																																																			
5.	<p>Delivery Points: *Coordinates are given without guarantee of accuracy</p> <table border="1"> <thead> <tr> <th>PoP Name</th> <th>Locality</th> <th>Province</th> <th>*Lat</th> <th>*Long</th> <th>Address</th> </tr> </thead> <tbody> <tr> <td>Dau PoP</td> <td>Dau</td> <td>Pampanga</td> <td>15.17977</td> <td>120.591238</td> <td>DAU Homesite, 2-A DAU Expressway, DAU, Mabalacat, Pampanga, Dau, Mabalacat, Pampanga</td> </tr> <tr> <td>Dagupan City PoP</td> <td>Dagupan City</td> <td>Pangasinan</td> <td>16.04399</td> <td>120.334307</td> <td>Poblacion Oeste, A. B. Fernandez West, Dagupan City, Pangasinan</td> </tr> <tr> <td>Batangas City PoP</td> <td>Batangas City</td> <td>Batangas</td> <td>13.76543</td> <td>121.063118</td> <td>Capitol Site, Batangas City, Batangas</td> </tr> <tr> <td>Puerto Princesa PoP</td> <td>Puerto Princesa City</td> <td>Palawan</td> <td>9.737894</td> <td>118.734449</td> <td>Burgos Street, Puerto Princesa City, Palawan</td> </tr> <tr> <td>Legaspi City PoP</td> <td>Legaspi City</td> <td>Albay</td> <td>13.14473</td> <td>123.753452</td> <td>Post-Telecom Bldg., Lapu-Lapu Street, Legaspi City, Albay</td> </tr> <tr> <td>Lipa City PoP</td> <td>Lipa City</td> <td>Batangas</td> <td>13.94113</td> <td>121.154497</td> <td>B. Morada Avenue, Lipa City</td> </tr> <tr> <td>Tacloban City PoP</td> <td>Tacloban City</td> <td>Leyte</td> <td>11.24506</td> <td>125.004744</td> <td>Post-Telecom Bldg., , Port Area, Tacloban City, Leyte</td> </tr> <tr> <td>Calbayog City PoP</td> <td>Calbayog City</td> <td>Western Samar</td> <td>12.07264</td> <td>124.596884</td> <td>Calbayog City, Western Samar</td> </tr> <tr> <td>Zamboanga City PoP</td> <td>Zamboanga City</td> <td>Zamboanga Del Sur</td> <td>6.902776</td> <td>122.07341</td> <td>Port Area, Brgy Zone IV, 7000 Zamboanga City, Port Area, Zamboanga City, Zamboanga del Sur</td> </tr> <tr> <td>Pagadian City PoP</td> <td>Pagadian City</td> <td>Zamboanga Del Sur</td> <td>7.828975</td> <td>123.438448</td> <td>Corner Urro and Alano Streets, , Pagadian City, Zamboanga del Norte</td> </tr> </tbody> </table>	PoP Name	Locality	Province	*Lat	*Long	Address	Dau PoP	Dau	Pampanga	15.17977	120.591238	DAU Homesite, 2-A DAU Expressway, DAU, Mabalacat, Pampanga, Dau, Mabalacat, Pampanga	Dagupan City PoP	Dagupan City	Pangasinan	16.04399	120.334307	Poblacion Oeste, A. B. Fernandez West, Dagupan City, Pangasinan	Batangas City PoP	Batangas City	Batangas	13.76543	121.063118	Capitol Site, Batangas City, Batangas	Puerto Princesa PoP	Puerto Princesa City	Palawan	9.737894	118.734449	Burgos Street, Puerto Princesa City, Palawan	Legaspi City PoP	Legaspi City	Albay	13.14473	123.753452	Post-Telecom Bldg., Lapu-Lapu Street, Legaspi City, Albay	Lipa City PoP	Lipa City	Batangas	13.94113	121.154497	B. Morada Avenue, Lipa City	Tacloban City PoP	Tacloban City	Leyte	11.24506	125.004744	Post-Telecom Bldg., , Port Area, Tacloban City, Leyte	Calbayog City PoP	Calbayog City	Western Samar	12.07264	124.596884	Calbayog City, Western Samar	Zamboanga City PoP	Zamboanga City	Zamboanga Del Sur	6.902776	122.07341	Port Area, Brgy Zone IV, 7000 Zamboanga City, Port Area, Zamboanga City, Zamboanga del Sur	Pagadian City PoP	Pagadian City	Zamboanga Del Sur	7.828975	123.438448	Corner Urro and Alano Streets, , Pagadian City, Zamboanga del Norte	
PoP Name	Locality	Province	*Lat	*Long	Address																																																															
Dau PoP	Dau	Pampanga	15.17977	120.591238	DAU Homesite, 2-A DAU Expressway, DAU, Mabalacat, Pampanga, Dau, Mabalacat, Pampanga																																																															
Dagupan City PoP	Dagupan City	Pangasinan	16.04399	120.334307	Poblacion Oeste, A. B. Fernandez West, Dagupan City, Pangasinan																																																															
Batangas City PoP	Batangas City	Batangas	13.76543	121.063118	Capitol Site, Batangas City, Batangas																																																															
Puerto Princesa PoP	Puerto Princesa City	Palawan	9.737894	118.734449	Burgos Street, Puerto Princesa City, Palawan																																																															
Legaspi City PoP	Legaspi City	Albay	13.14473	123.753452	Post-Telecom Bldg., Lapu-Lapu Street, Legaspi City, Albay																																																															
Lipa City PoP	Lipa City	Batangas	13.94113	121.154497	B. Morada Avenue, Lipa City																																																															
Tacloban City PoP	Tacloban City	Leyte	11.24506	125.004744	Post-Telecom Bldg., , Port Area, Tacloban City, Leyte																																																															
Calbayog City PoP	Calbayog City	Western Samar	12.07264	124.596884	Calbayog City, Western Samar																																																															
Zamboanga City PoP	Zamboanga City	Zamboanga Del Sur	6.902776	122.07341	Port Area, Brgy Zone IV, 7000 Zamboanga City, Port Area, Zamboanga City, Zamboanga del Sur																																																															
Pagadian City PoP	Pagadian City	Zamboanga Del Sur	7.828975	123.438448	Corner Urro and Alano Streets, , Pagadian City, Zamboanga del Norte																																																															
6.	Payment shall be made upon the complete delivery, installation, testing and acceptance of ALL the Generator Sets to their delivery points.																																																																			
7.1.	All Generator Sets, including its standard accessories, must undergo the "Test Procedures Integrated Power System", supervised by FOO Cluster acceptance representatives.																																																																			
7.2.	Procedures are as follows, showing actual results and to mark if results did pass or fail																																																																			
7.2.1.	<p>For Diesel Generator</p> <p>1. Manual Start</p> <p>a. Engine should start and run continuously until manually stopped without any faults or alarms on the control panel.</p> <p>b. Record all reading in control panel</p>																																																																			



	<p>2. 4 minutes Run test (without load)</p> <p>a. The engine should run continuously for 4 minutes until manually stopped without any faults or alarms on the control panel.</p> <p>b. Record all reading in control panel</p> <p>3. 2 hours Run test (with load)</p> <p>a. The engine should run continuously from 2 hours until manually stopped without any faults or alarms on the control panel</p> <p>b. Test load should be provided by bidder.</p> <p>4. Battery Charging System</p> <p>a. Battery voltage reading must be above normal battery level</p> <p>5. Oil and Liquid Coolant levels</p> <p>a. Level should be within the recommended level by manufacturer</p>	
7.2.2.	<p>For ATS</p> <p>1. Power outage transfer test</p> <p>a. Must be able to show that the Genset automatically starts and power supply of the whole electrical system is transferred to the genset.</p> <p>2. Restored Power transfer test</p> <p>a. Must be able to show that power supply for the whole electrical system is transferred from the Genset to the original source and genset is automatically turned off subsequently</p>	
7.2.3.	<p>Full System Test</p> <p>1. Simulation of power outage</p> <p>a. Must be able to show that the Genset automatically starts and power supply of the whole electrical system is transferred to the genset within the time set.</p> <p>2. Simulation of restored power</p> <p>a. Must be able to show that power supply for the whole electrical system is transferred from the genset to the original source and genset is automatically turned off subsequently</p> <p>b. Must be able to show that normal power supply is restored</p>	
8.1.	Franchise Requirements. Non-franchise holders may participate in this tender but without prejudice to other legal requirements, particularly with respect to the provisioning of commercial services outside the PROJECT.	
8.2.	Installations Costs and Other One Time Charges (OTC). No OTCs shall be allowed.	
8.3.	Taxes & Other Fees. All proposals shall be inclusive of all taxes, installation charges and other one-time costs, and other fees.	

Name of Company

Signature Over Printed Name
Of Authorized Representative

Date

Supplemental Bid Bulletin No. 3

Supply, Delivery, Installation, Testing and Acceptance of One Lot Brand New Power Generators for the Ten (10) Point of Presence Sites

BAC4FREEWIFI-2016-02-001



ICT OFFICE BAC4FREEWIFI REVISED CHECKLIST OF REQUIREMENTS FOR BIDDERS

Name of Company : _____
Project : **SUPPLY, DELIVERY, INSTALLATION, TESTING AND ACCEPTANCE OF ONE LOT OF BRAND NEW POWER GENERATORS FOR THE TEN (10) POINT OF PRESENCE SITES**
Bid Ref No. : **BAC4FREEWIFI-2016-02-001**

APPROVED BUDGET FOR THE CONTRACT : PhP9,500,000.00

Ref. No.	Particulars	
ENVELOPE 1: ELIGIBILITY AND TECHNICAL DOCUMENTS		
ELIGIBILITY DOCUMENTS		
CLASS "A" DOCUMENTS		
12.1	(a.1.) ELIGIBILITY DOCUMENTS	
	i.	Registration certificate from the Securities and Exchange Commission (SEC), Department of Trade and Industry (DTI) for sole proprietorship, or Cooperative Development Authority (CDA) for cooperatives
	ii.	Business/Mayor's permit for 2016 issued by the city or municipality where the principal place of business of the prospective bidder is located
	iii.	Valid and Current Tax Clearance per Executive Order 398, Series of 2005, as finally reviewed and approved by the BIR.
	iv.	Statement of all its Ongoing (including awarded contract/s not yet started, if any) within the last three (3) Years, (Annex I)
	v.	Statement of Completed Single Largest Contract from January 2010 up to the day before the deadline for the submission bids of similar in nature equivalent to at least fifty percent (50%) of the ABC. Annex I-A
	vi.	Copy of 2014 Annual Income Tax Return submitted through BIR's Electronic Filing and Payment System (EFPS) together with the following Audited Financial Statements for 2014 and 2013 (in comparative form or separate reports): a) Copy of Independent Auditor's Report; b) Balance Sheet (Statement of Financial Position); c) Income Statement (Statement of Comprehensive Income); Each of the above statements must have stamped " received " by the Bureau of Internal Revenue (BIR) or its duly accredited and authorized institutions
	vii.	Duly signed Net Financial Contracting Capacity Computation (NFCC) per Annex II , in accordance with ITB Clause 5.5 NFCC = [(Current Assets minus Current Liabilities) (K)] minus the value of all outstanding or uncompleted portions of the projects under ongoing contracts, including awarded contracts yet to be started coinciding with



	<p>the contract to be bid. Where: K: 10 for a contract duration of one year or less, 15 for a contract duration of more than one year up to two years, and 20 for a contract duration of more than two years.</p> <p>Notes:</p> <ol style="list-style-type: none"> The values of the bidder's current assets and current liabilities shall be based on the data submitted to BIR through its Electronic Filing and Payment System. Value of all outstanding or uncompleted contracts refers those listed in Annex-I. The detailed computation using the required formula must be shown as provided above. 									
CLASS "B" DOCUMENTS (FOR JOINT VENTURE)										
	<p>i. For Joint Ventures, Bidder to submit either:</p> <ol style="list-style-type: none"> Copy of the JOINT VENTURE AGREEMENT (JVA) in case the joint venture is already in existence, or Copy of Protocol / Undertaking of Agreement to Enter into Joint Venture signed by all the potential joint venture partners stating that they will enter into and abide by the provisions of the JVA in the instance that the bid is successful. (Annex III) <p><u>The JVA or the Protocol/Undertaking of Agreement to Enter into Joint Venture (Annex III) must include/specify the company/partner and the name of the office designated as authorized representative of the Joint Venture.</u></p> <p>For Joint Venture, the following documents must likewise be submitted:</p> <p>For Joint Venture Between Two (2) Local Companies, each partner should submit:</p> <ol style="list-style-type: none"> Registration Certificate from the Securities and Exchange Commission (SEC) for corporations, Department of Trade and Industry (DTI) for sole proprietorship, or Cooperative Development Authority (CDA) for cooperatives; Business/Mayor's permit for 2016 issued by the city or municipality where the principal place of business of the prospective bidder is located; Valid and Current Tax Clearance per Executive Order 398, Series of 2005, as finally reviewed and approved by the BIR. 									
	For item (iv) to (vii) of the required eligibility documents, submission by any of the Joint Venture partner constitutes compliance.									
TECHNICAL DOCUMENTS										
12.1 (b)(i)	<p>Bid security shall be issued in favor of the INFORMATION AND COMMUNICATIONS TECHNOLOGY OFFICE (ICT Office) valid at least one hundred twenty (120) days after date of bid opening in any of the following forms:</p> <ol style="list-style-type: none"> BID SECURING DECLARATION per Annex IV; or Cashier's / Manager's Check equivalent to at least 2% of ABC issued by a Local or Universal or Local Commercial Bank. 									
	<table border="1"> <thead> <tr> <th>Description</th> <th>Qty</th> <th>ICT Office ABC</th> <th>Bid Security: Cash, Cashier's /</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Description	Qty	ICT Office ABC	Bid Security: Cash, Cashier's /					
Description	Qty	ICT Office ABC	Bid Security: Cash, Cashier's /							

Supplemental Bid Bulletin No. 3

Supply, Delivery, Installation, Testing and Acceptance of One Lot Brand New Power Generators for the Ten (10) Point of Presence Sites

BAC4FREEWIFI-2016-02-001



			Total Price	Manager's Check, (2%) (P)
	Supply, Delivery, Installation, Testing And Acceptance of One Lot Of Brand New Power Generators For The Ten (10) Point Of Presence Sites	1 Lot	P9,500,000.00	P 190,000.00
12.1 (b)(ii)	Duly signed and completed Technical Bid Form. Bidder must use, accomplish and submit the Technical Bid Form hereto attached as Annex V .			

12.1 (b)(x)	Proof of Authority of the Bidder's authorized representative/s: a) FOR SOLE PROPRIETORSHIP (IF OWNER OPTS TO APPOINT A REPRESENTATIVE): Duly notarized Special Power of Attorney b) FOR CORPORATIONS, COOPERATIVE OR THE MEMBERS OF THE JOINT VENTURE: Duly notarized Secretary's Certificate evidencing the authority of the designated representative/s. IN THE CASE OF UNINCORPORATED JOINT VENTURE: Each member shall submit a separate Special Power of Attorney and/or Secretary's Certificate evidencing the authority of the designated representative/s.
12.1 (b)(xi)	Omnibus Sworn Statements using the form prescribed. (Annex VI)
	a) Authority of the designated representative
	b) Non-inclusion of blacklist or under suspension status
	c) Authenticity of Submitted Documents
	d) Authority to validate Submitted Documents
	e) Disclosure of Relations
	f) Compliance with existing labor laws and standards
g) Did not pay any form of consideration	
Section VI.	Revised Schedule of Requirements as of 10 March 2016
Section VII.	Revised Technical Specifications as of 18 March 2016

ENVELOPE 2: FINANCIAL DOCUMENTS

13.1 (a)	Completed and signed Financial Bid Form. Bidder must use, accomplish and submit Financial Bid Form hereto attached Annex VII .		
	Description	Qty	ABC P (VAT Inclusive Total)
	Supply, Delivery, Installation, Testing And Acceptance - One Lot Of Brand New Power Generators For The Ten (10) Point Of Presence Sites	1 Lot	P 9,500,000.00
	The ABC is inclusive of VAT. Any proposal with a financial component exceeding the ABC shall not be accepted. Further, the sum of bid for each item indicated in the Detailed Financial Breakdown per Annex VII-A must be equal to the signed and submitted Financial Bid Form per Annex VII.		
	Detailed Financial Breakdown per Revised Annex VII-A as of 10 March 2016		
15.4(a)	Completed "For Goods Offered from Abroad" and/or "For Goods Offered From		

Supplemental Bid Bulletin No. 3

Supply, Delivery, Installation, Testing and Acceptance of One Lot Brand New Power Generators for the Ten (10) Point of Presence Sites

BAC4FREEWIFI-2016-02-001



(i) & 15.4(b) (ii)	Within the Philippine” Forms per Revised Annex VIII-A as of 10 March 2016 and Revised Annex VIII-B as of 10 March 2016, whichever is applicable.	
13.1 (b)	If the Bidder claims preference as a Domestic Bidder or Domestic Entity, a Certification from the DTI, SEC or CDA to be enclosed pursuant to the Revised IRR of R.A. 9184.	
NOTE:	In case of inconsistency between the Checklist of Requirements for Bidders and the provisions in the Instruction to Bidders/Bid Data Sheet, the Instruction to Bidders/Bid Data Sheet shall prevail	

Supplemental Bid Bulletin No. 3

Supply, Delivery, Installation, Testing and Acceptance of One Lot Brand New Power Generators for the Ten (10) Point of Presence Sites

BAC4FREEWIFI-2016-02-001